



September 1, 2021

Mr. Floro Villanueva, Jr.
Business Administrator
Denville Board of Education
240 Homans Avenue
Closter, NJ 07624

Re: Lead in Drinking Water Services per NJAC 6A:26
Hillside School, 340 Homans Avenue, Closter, NJ 07624
Tenakill School, 275 High Street, Closter, NJ07624


Dear Mr. Villanueva,

New Wave is pleased to submit this lead in drinking water report for the Closter Board of Education. This report details the methods and findings of the comprehensive lead in drinking water services as per New Jersey state regulations (amendments to N.J.A.C 6A:26 Educational Facilities) performed at the various schools in the Closter School District, located at the above referenced addresses on July 21, 2021.

Best Regards,

Nadine Bello

Nadine Bello, MS, RPIH, CIEC, AST
New Wave Engineering, LLC



Lead in Drinking Water Report

Closter Board of Education
340 Homans Avenue
Closter, NJ 07624

August 2021

Prepared for:
Closter Board of Education
340 Homans Avenue
Closter, NJ 07624

Prepared by:
New Wave Engineering, LLC
PO Box 4124
Wayne, New Jersey 07474

Table of Content

| | |
|--|--------|
| EXECUTIVE SUMMARY..... | Page 1 |
| 1.0 PROJECT BACKGROUND..... | Page 2 |
| 2.0 LEAD IN DRINKING WATER..... | Page 2 |
| 3.0 DRINKING WATER SAMPLING METHODOLOGY..... | Page 3 |
| 4.0 DRINKING WATER ANALYSIS RESULTS..... | Page 4 |
| 5.0 CONCLUSIONS & RECOMMENDATIONS..... | Page 7 |
| 6.0 DISCLAIMER..... | Page 7 |
| 7.0 CLOSING..... | Page 8 |

APPENDIX A Chain of Custody and Lab Results

Executive Summary of Lead in Drinking Water Services

August 2021

New Wave Engineering was retained to conduct a first draw “lead in drinking water sampling” at the district’s school buildings located within the Closter Board of Education in July of 2021. Water samples were collected from designated drinking water outlets at the following schools:

All samples were collected according to the regulatory guidelines outlined in the amendments to the N.J.A.C. 6A:26: Educational Facilities (July 2016) and its supporting documentation.

- **Hillside School**
- **Tenakill School**

First draw sample results indicated that water sources sampled at locations from the schools, exhibited no lead levels above the Regulatory Action Level of .015mg/l, or its equivalent: 15ppbs. With no potable water sources in exceedance of the Action Level, no remediation of the water outlets is required. Continue with the Districts plumbing maintenance plan and replace any water filters as required by the manufacture’s recommendations. All plumbing repairs and upgrades must be documented in the district’s “Lead in Drinking Water” plan. According to State regulations, the next scheduled lead in water testing shall occur in three years, during the school year 2024/2025.

1.0 PROJECT BACKGROUND

New Wave Engineering was contacted by the Closter Board of Education (the "Client") to perform lead in drinking water sampling to determine the lead content of drinking water from sources throughout the school facilities. Additionally, as per State regulations, New Wave was contracted to update a Quality Assurance Project Plan (QAPP) and a Sampling Plan (SP), including: a Drinking Water Outlet Inventory, Filter Inventory, and Outlet Location Schematic in conjunction with the District's Buildings and Grounds Director.

The purpose of lead in drinking water sampling is to determine if any sampled drinking water sources exhibit lead levels exceeding the Regulatory Action Level of 15 parts per billion (ppb) which may also be designated as: .015mg/l. Drinking water concentration points included: any water sources from which a student, staff, or faculty may reasonably drink or from which the water may be used for cooking or beverage preparation, including, but not limited to, water coolers/bubblers, kitchen faucets, Nurse's Office faucets, and Faculty/Staff lounges.

For further information on guidance protocols and Action Levels that were followed please refer to: The EPA's Revised Technical Guidance - *"3Ts for Reduced Lead in Drinking Water in Schools"* and the Guidance Document from NJDEP Division of Water Supply and Geoscience — *"Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water"*.

2.0 LEAD IN DRINKING WATER

Lead is a toxic substance that can be harmful to human health. As compared to adults, children are more susceptible to the detrimental health effects of lead, as their nervous systems are not yet fully developed. Exposure to lead can occur in a variety of ways including through food, soil, deteriorating lead-based paint, and drinking water. Lead can leach into drinking water from plumbing materials such as pipes and solder, as well as brass plumbing fixtures. For this investigation, planning, preparation, methodology, sampling, and follow up actions were conducted according to the technical guidance provided by New Jersey following the adoption of amendments to N.J.A.C. 6A:26: *"Educational Facilities, requiring the sampling of drinking water for Lead in Schools"*

3.0 DRINKING WATER SAMPLING METHODOLOGY

New Wave collected drinking water samples from water outlets throughout each school building. At each collection point, New Wave filled a 250 milliliter (ml) wide-mouth high density polyethylene (HDPE) sample collection bottle from the designated water source. Samples were collected after the water in each building had not been used for at least 8 hours, but not more than 48 hours. The initial sample at each collection point represents the first draw sample. The first draw sample is representative of the water from the end point of the water source (i.e., the bubbler/bottle filler or tap).

A field blank using lead-free laboratory reagent water was also collected for each Facility during the sampling event to rule out contamination of samples during the collection and transportation process. All samples were recorded utilizing proper chain of custody documents and couriered to *Garden State Laboratory*, a New Jersey certified laboratory (*NJ Lab ID #20044*) located in Hillside, New Jersey for analysis via EPA method 200.80.

During the initial sampling event on July 21, New Wave collected the following number of samples at each School Building:

Hillside School

- 1) 1 Field Blank Sample
- 2) 21 First draw samples

Tenakill School

- 1) 1 Field Blank Sample
- 2) 16 First draw samples

For a complete drinking water outlet inventory and sampling location diagram for each facility, please refer to the Sampling Plan, dated May 2017. Updates to this documentation can be found in the Field Log Book for each facility.

4.0 DRINKING WATER ANALYSIS RESULTS

The analytical “lead in drinking water results” for each first draw sample is listed in Tables below:

Table 1: Analytical Lead Results for First Draw Water Samples Collected from **Hillside School** July 21, 2021

| Sample I.D. | Type of Collection Point | Lead Concentration (mg/l) | Above Regulatory Action Level? |
|---------------|--------------------------|---------------------------|--------------------------------|
| CLOS-HS-21-1 | Hallway C136 W/F right | < 0.00100 | No |
| CLOS-HS-21-2 | Hallway C136 W/F left | < 0.00100 | No |
| CLOS-HS-21-3 | Rm 136 Bubler | < 0.00100 | No |
| CLOS-HS-21-4 | Nurse’s Office Sink | < 0.00326 | No |
| CLOS-HS-21-5 | Copy Room Sink | < 0.00100 | No |
| CLOS-HS-21-6 | Room 137 Bubler | < 0.0056 | No |
| CLOS-HS-21-7 | Room 138 Bubler | < 0.00125 | No |
| CLOS-HS-21-8 | Room 141 Bubler | < 0.00100 | No |
| CLOS-HS-21-9 | Room 153 Bubler | < 0.00100 | No |
| CLOS-HS-21-10 | Room 156 Bubler | < 0.00100 | No |
| CLOS-HS-21-11 | Room 159 Bubler | < 0.00100 | No |
| CLOS-HS-21-12 | Room 162 Bubler | < 0.00100 | No |
| CLOS-HS-21-13 | Gym Hall B/F | < 0.00100 | No |
| CLOS-HS-21-14 | Gym Hall Bubler | < 0.00100 | No |
| CLOS-HS-21-15 | Kitchen Sink | < 0.00267 | No |
| CLOS-HS-21-16 | Hallway by C106 B/F | < 0.00100 | No |
| CLOS-HS-21-17 | Hallway by C106 Bubler | < 0.00100 | No |
| CLOS-HS-21-18 | Room 100 Bubler | < 0.00100 | No |
| CLOS-HS-21-19 | Room 102 Bubler | < 0.00100 | No |
| CLOS-HS-21-20 | Hallway D110 B/F | < 0.00100 | No |
| CLOS-HS-21-21 | Hallway D110 Bubler | < 0.00100 | No |
| CLOS-HS-21-22 | FIELDBLANK | < 0.00100 | No |

BF= Bottle Filler Station W/F= Water Fountain B= Bubler S=Sink

Table 2: Analytical Lead Results for First Draw Water Samples
 Collected from **Tenakill School** taken on July 21, 2021

| Sample ID. | Type of Collection Point | Lead Concentration (mg/l) | Above Regulatory Action Level?! |
|--------------|--------------------------|---------------------------|---------------------------------|
| CLOS-T-21-1 | Faculty Room Sink | < 0.00100 | No |
| CLOS-T-21-2 | Nurse's Room Sink | < 0.00119 | No |
| CLOS-T-21-3 | Hallway by Gym B/F | < 0.00100 | No |
| CLOS-T-21-4 | Hallway by Gym Bubbler | < 0.00100 | No |
| CLOS-T-21-5 | Kitchen Prep Sink | < 0.00100 | No |
| CLOS-T-21-6 | In Gym B/F | < 0.00100 | No |
| CLOS-T-21-7 | In Gym Bubbler | < 0.00100 | No |
| CLOS-T-21-8 | Main Office Sink | < 0.00100 | No |
| CLOS-T-21-9 | Boiler Hallway W/F | < 0.00100 | No |
| CLOS-T-21-10 | Hallway by 206 B/F | < 0.00100 | No |
| CLOS-T-21-11 | Hallway by 206 Bubbler | < 0.00100 | No |
| CLOS-T-21-12 | Hallway by B213 W/F | < 0.00894 | No |
| CLOS-T-21-13 | Hallway by 202 B/F | < 0.00100 | No |
| CLOS-T-21-14 | Hallway by B202 Bubbler | < 0.00100 | No |
| CLOS-T-21-15 | Hallway by A204 B/F | < 0.00100 | No |
| CLOS-T-21-16 | Hallway by A204 Bubbler | < 0.00100 | No |
| CLOS-T-21-17 | FIELD BLANK | < 0.00100 | No |

B/F= Bottle Filler B= Bubbler W/F= Water Fountain S= Sink

All laboratory analytical results of first-draw samples were compared to the NJDEP's Regulatory Action Level of 15.5 ppb or .015 mg/l for lead. Analysis of lead in the first draw drinking water samples indicated that, at the time of the sampling event, no water sources tested exceeded the action level.

5.0 CONCLUSIONS & RECOMMENDATIONS

New Wave collected first draw samples from drinking water sources throughout the Closter Board of Education school facilities. First draw sample results indicated that no water outlet sources *exceeded* the regulatory action level of 15 ppb or .015mg/l. In conclusion of the comprehensive “lead in drinking water” services, New Wave offers the following recommendations:

- Continue to monitor lead in drinking water levels as part of a regular sampling and maintenance plan, per New Jersey State regulations.
- Implement an aerator cleaning maintenance program to prevent the build up of debris behind the aerator screen which may contribute to elevated lead levels.
- Enter all filter maintenance, aerator maintenance, plumbing repairs/changes and any other important information into the *Field Log Book* for each School.
- Use only cold water for food and beverage preparation, as hot water is more likely to contribute to the corrosion of plumbing materials and therefore may contain a greater level of water contaminants from the plumbing system.

6.0 Disclaimer

This investigation focused on lead in drinking water. No other heavy metals or additional contaminants were sampled for/or analyzed. Note: Lead concentrations in water can change as water continues to move through the water system.

Each sample taken was a “grab sample” and represents lead concentrations only at the specific time of collection and may vary based upon the water usage in the facility. Interpretation of these results is only valid if the facility is serviced by a municipal water supplier or water utility.

Our lead sampling event was in response to recent amendments to N.J.A.C. 6A:26i *Educational Facilities* dated July 13, 2016, which requires testing for lead in drinking water of public and charter school districts with retesting every three years.

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment.

New Wave Engineering, LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for the above noted client. New Wave Engineering, LLC assumes no liability with regards

to the use of this information or decisions which are made regarding the subject properties. It is at the discretion of the School District, given the results and information in this report, to use their own best judgment to determine any appropriate course of action.

7.0 Closing

The drinking water in the Closter Public Schools is below the action level of 15 ppb or .015 mg/l.

Thank you for utilizing New Wave to assist your District with this project. Please do not hesitate to call if you have any questions relating to this report or for any other environmental health and safety concerns.

APPENDIX A
CHAIN OF CUSTODY
AND
LAB RESULTS



Garden State Laboratories, Inc.

Report Date: 07/30/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Closter Board of Education - NW
340 Homans Ave

Closter, NJ 07624

Laboratory Director:

Attention: Jerry Bello

Client Number: CLO02

Sample ID: CLOSH-21-1-Hallway C136
WF/Hillside School

Lab Sample ID: 210721058-01

Site: Collection Date/Time: 07/21/2021 06:00

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:14 | |

Sample ID: CLOSH-21-2 Hallway C136
WF/Hillside School

Lab Sample ID: 210721058-02

Site: Collection Date/Time: 07/21/2021 06:00

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:25 | |

Sample ID: CLOSH-21-3 Rm 136
Bubbler/Hillside School

Lab Sample ID: 210721058-03

Site: Collection Date/Time: 07/21/2021 06:01

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:29 | |



Sample ID: CLOSH-21-4 Nurse's Sink/Hillside School Lab Sample ID: 210721058-04
 Site: Collection Date/Time: 07/21/2021 06:01
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|---------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | 0.00326 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:32 | |

Sample ID: CLOSH-21-5 Copy Rm Sink/Hillside School Lab Sample ID: 210721058-05
 Site: Collection Date/Time: 07/21/2021 06:02
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:36 | |

Sample ID: CLOSH-21-6 Room 137-Bubbler/Hillside School Lab Sample ID: 210721058-06
 Site: Collection Date/Time: 07/21/2021 06:02
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|---------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | 0.00156 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:40 | |

Sample ID: CLOSH-21-7 Room 138-Bubbler/Hillside School Lab Sample ID: 210721058-07
 Site: Collection Date/Time: 07/21/2021 06:03
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|---------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | 0.00125 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:44 | |

Sample ID: CLOSH-21-8 Room 141-Bubbler/Hillside School Lab Sample ID: 210721058-08
 Site: Collection Date/Time: 07/21/2021 06:04
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:47 | |



Sample ID: CLOSH-21-9 Room 153-
Bubbler/Hillside School Lab Sample ID: 210721058-09

Site: Collection Date/Time: 07/21/2021 06:05

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 09:59 | |

Sample ID: CLOSH-21-10 Room 156-
Bubbler/Hillside School Lab Sample ID: 210721058-10

Site: Collection Date/Time: 07/21/2021 06:06

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:02 | |

Sample ID: CLOSH-21-11-Room 159
Bubbler/Hillside School Lab Sample ID: 210721058-11

Site: Collection Date/Time: 07/21/2021 06:07

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:06 | |

Sample ID: CLOSH-21-12 Room 162
Bubbler/Hillside School Lab Sample ID: 210721058-12

Site: Collection Date/Time: 07/21/2021 06:08

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:10 | |

Sample ID: CLOSH-21-13 Gym Hall
Buttler/Hillside School Lab Sample ID: 210721058-13

Site: Collection Date/Time: 07/21/2021 06:10

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/28/21 10:02 | |



Sample ID: CLOSH-21-14 Gym Hall-Bubbler/Hillside School Lab Sample ID: 210721058-14
 Site: Collection Date/Time: 07/21/2021 06:10
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:14 | |

Sample ID: CLOSH-21-15 Kitchen-Sink/Hillside School Lab Sample ID: 210721058-15
 Site: Collection Date/Time: 07/21/2021 06:11
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|---------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | 0.00267 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:17 | |

Sample ID: CLOSH-21-16 Hallway by C106/Hillside School Lab Sample ID: 210721058-16
 Site: Collection Date/Time: 07/21/2021 06:12
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:21 | |

Sample ID: CLOSH-21-17 Hallway by C106 Bub/Hillside School Lab Sample ID: 210721058-17
 Site: Collection Date/Time: 07/21/2021 06:12
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:25 | |

Sample ID: CLOSH-21-18 Room 100 Bubbler/Hillside School Lab Sample ID: 210721058-18
 Site: Collection Date/Time: 07/21/2021 06:13
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:29 | |



Sample ID: CLOSH-21-19 Room 102 Bubbler/Hillside School
 Lab Sample ID: 210721058-19
 Site: Collection Date/Time: 07/21/2021 06:14
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:32 | |

Sample ID: CLOSH-21-20 Hallway D110 BF/Hillside School
 Lab Sample ID: 210721058-20
 Site: Collection Date/Time: 07/21/2021 06:15
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:48 | |

Sample ID: CLOSH-21-By D110 Bubbler/Hillside School
 Lab Sample ID: 210721058-21
 Site: Collection Date/Time: 07/21/2021 06:15
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 10:51 | |

Sample ID: CLOSH-21-Field Blank/Hillside School
 Lab Sample ID: 210721058-22
 Site: Collection Date/Time: 07/21/2021 06:15
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:03 | |

Sample ID: Clost-21-1 Faculty Room Sink/ Tenakill School
 Lab Sample ID: 210721058-23
 Site: Collection Date/Time: 07/21/2021 06:40
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:06 | |



Sample ID: Clost-21-2 Nurses' Room Sink/ Tenakill School Lab Sample ID: 210721058-24
 Site: Collection Date/Time: 07/21/2021 06:40
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|---------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | 0.00119 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:10 | |

Sample ID: Clost-21-3 Hallway by Gym off Bottle Filler/ Tenakill School Lab Sample ID: 210721058-25
 Site: Collection Date/Time: 07/21/2021 06:41
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:14 | |

Sample ID: Clost-21-4 Hallway by Gym off Bubbler/ Tenakill School Lab Sample ID: 210721058-26
 Site: Collection Date/Time: 07/21/2021 06:41
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:18 | |

Sample ID: Clost-21-5 Kitchen Prep Sink/ Tenakill School Lab Sample ID: 210721058-27
 Site: Collection Date/Time: 07/21/2021 06:43
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:21 | |

Sample ID: Clost-21-6-In Gym-Bottle Fille/ Tenakill School Lab Sample ID: 210721058-28
 Site: Collection Date/Time: 07/21/2021 06:43
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:33 | |



Sample ID: Clost-21-7-In Gym-Bubbler/
Tenakill School Lab Sample ID: 210721058-29

Site: Collection Date/Time: 07/21/2021 06:44

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:36 | |

Sample ID: Clost-21-8 Main off Sink/
Tenakill School Lab Sample ID: 210721058-30

Site: Collection Date/Time: 07/21/2021 06:44

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:40 | |

Sample ID: Clost-21-9 By Boiler Hallway
-WF/ Tenakill School Lab Sample ID: 210721058-31

Site: Collection Date/Time: 07/21/2021 06:45

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:44 | |

Sample ID: Clost-21-10-Hallway by 206
BF/ Tenakill School Lab Sample ID: 210721058-32

Site: Collection Date/Time: 07/21/2021 06:45

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:48 | |

Sample ID: Clost-21-11-Hallway by 206
Bubbler/ Tenakill School Lab Sample ID: 210721058-33

Site: Collection Date/Time: 07/21/2021 06:45

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:51 | |



Sample ID: Clost-21-12 Hallway by B213 WF/ Tenakill School Lab Sample ID: 210721058-34
 Site: Collection Date/Time: 07/21/2021 06:46
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|---------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | 0.00894 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:55 | |

Sample ID: Clost-21-13 Hallway by A202 BF/ Tenakill School Lab Sample ID: 210721058-35
 Site: Collection Date/Time: 07/21/2021 06:47
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 11:59 | |

Sample ID: Clost-21-14 Hallway by B202 Bubbler/ Tenakill School Lab Sample ID: 210721058-36
 Site: Collection Date/Time: 07/21/2021 06:47
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 12:03 | |

Sample ID: Clost-21-15 Hallway by A204 BF/ Tenakill School Lab Sample ID: 210721058-37
 Site: Collection Date/Time: 07/21/2021 06:48
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/28/21 10:08 | |

Sample ID: Clost-21-16 Hallway by A204 Bubbler/ Tenakill School Lab Sample ID: 210721058-38
 Site: Collection Date/Time: 07/21/2021 06:48
 Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|----------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 12:06 | |



Sample ID: Clost-21-17 - Field Blank/
Tenakill School Lab Sample ID: 210721058-39

Site: Collection Date/Time: 07/21/2021

Matrix: Potable water Sample Type: Grab

| Analyte | Method | DF | Sample Result | MCL | Rep. Limit | MDL | Lab Cert No. | Analysis Date/Time | Qualifiers |
|-------------------------|-----------|----|-------------------|-------|------------|-------|--------------|--------------------|------------|
| Lead, Total Recoverable | EPA 200.8 | 1 | < 0.00100 mg/l | 0.015 | 0.00100 | 6E-05 | 20044 | 07/29/21 12:22 | |

*DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*



Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.58
20200

Page of

GSL CLIENT # C1002

MICRO#

CHEM. # 210721058-01-05

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **CLOSTER Bd of Education** Contact/Authorized by: **JERRY BELLO**
 Mailing Address: **340 HOMANS AVE** Phone: **973-981-4850**
 City/State/Zip: **CLOSTER, NJ 07624** Email: **JERNALTD@aol.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**
 SAMPLE LOCATION: **HILLSIDE SCHOOL**

| Grab | Comp | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | | CONTAINER INFORMATION | | | |
|------|------|----------------------------|-------------------|------|----|----|--|-------------|-----------------------|-------|------|--------|
| | | | Date | Time | AM | PM | <input type="checkbox"/> List attached | Total Pages | No. | Type* | Size | Pres.* |
| X | | CLOSH-21-1 HALLWAY C136 WF | 07/21/21 | 6:00 | X | | LEAD (FIRST DRAW) | 58-01 | 1 | P | 250 | A |
| X | | CLOSH-21-2 HALLWAY C136 WF | 07/21/21 | 6:00 | X | | LEAD (FIRST DRAW) | 58-02 | 1 | P | 250 | A |
| X | | CLOSH-21-3 Rm 136 Bubbler | 07/21/21 | 6:01 | X | | LEAD (FIRST DRAW) | 58-03 | 1 | P | 250 | A |
| X | | CLOSH-21-4 NURSE'S SINK | 07/21/21 | 6:01 | X | | LEAD (FIRST DRAW) | 58-04 | 1 | P | 250 | A |
| X | | CLOSH-21-5 COPY RM SINK | 07/21/21 | 6:02 | X | | LEAD (FIRST DRAW) | 58-05 | 1 | P | 250 | A |

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: **XX** Standard Rush (IF RUSH REQUESTED) Rush Due by: **4 WEEK TURN AROUND**

SEND TO:

REPORT FORMAT: Standard Report Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

| | | |
|--|------------|----------------------------|
| Sampled by (PRINT): JERRY BELLO | Signature: | Date/Time: 07/21/21 |
| Client/Client's Representative (PRINT): MAXX MAZZA | Signature: | Date/Time: |
| 1. Received/Relinquished by (PRINT): D. [Signature] | Signature: | Date/Time: 7/21/21 |
| 2. Received/Relinquished by (PRINT): | Signature: | Date/Time: |

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.5°C
 NO SOC

Page _____ of _____

GSL CLIENT # CLO02

MICRO # _____
 CHEM. # 210721058-06-10

SAMPLE REC'D BY: _____
 GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Closter Board of Education Contact/Authorized by: Jerry Bello
 Mailing Address: 340 Homans Ave Phone: 973-981-4850
 City/State/Zip: Closter NJ 07624 Email: _____

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Field Blanks Hillside School

| Grab | Comp | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | CONTAINER INFORMATION | | | | Lab # Extension |
|------|------|----------------------------------|-------------------|------|----|----|-----------------------------------|-----------------------|-------|-------|--------|--------------------|
| | | | Date | Time | AM | PM | | No. | Type* | Size | Pres.* | |
| X | | Closter-21-6 Room 137 - bubbler | 07/21/21 | 6:02 | X | | Lead (First Draw) 58-06 | 1 | P | 250ml | A | |
| X | | Closter-21-7 Room 138 - bubbler | 07/21/21 | 6:03 | X | | Lead (First Draw) 58-07 | 1 | P | 250ml | A | |
| X | | Closter-21-8 Room 141 - bubbler | 07/21/21 | 6:04 | X | | Lead (First Draw) 58-08 | 1 | P | 250ml | A | |
| X | | Closter-21-9 Room 153 - bubbler | 07/21/21 | 6:05 | X | | Lead (First Draw) 58-09 | 1 | P | 250ml | A | |
| X | | Closter-21-10 Room 156 - bubbler | 07/21/21 | 6:06 | X | | Lead (First Draw) 58-10 | 1 | P | 250ml | A | |

*Container type: P = Plastic G = Glass A = Amber Glass T = Sterile Thro V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: XX Standard Rush (IF RUSH REQUESTED) Rush Due by: 4 week Turnaround
 REPORT FORMAT: Standard Report Other/Specify: _____
 Standard Report + E2 PWS ID#: _____

SEND TO: _____
 DATE/TIME: _____
 METHOD OF SHIPMENT: _____

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note: _____

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello Signature: *[Signature]*
 Client/Client's Representative (PRINT): MAXX MAZZA Signature: _____ Date/Time: _____
 1. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: _____
 2. Received/Relinquished by (PRINT): *[Signature]* Signature: *[Signature]* Date/Time: 7/21/21 11:54

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TN1, NY Dept. of Health #11550 and PADEP #68-03680

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.5°C
 N250C

Page _____ of _____

GSL CLIENT # CLO02

MICRO #

CHEM. # 210721058-11-15

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Closter Board of Education Contact/Authorized by: Jerry Bello
 Mailing Address: 340 Homans Ave Phone: 973-981-4850
 City/State/Zip: Closter NJ 07624 Email:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Field Blanks Hillside School

| Grab | Comp | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | CONTAINER INFORMATION | | | | Lab # Extension |
|------|------|----------------------------------|-------------------|------|----|----|-----------------------------------|-----------------------|-------|-------|--------|--------------------|
| | | | Date | Time | AM | PM | | No. | Type* | Size | Pres.* | |
| X | | Closter-11-Room 159 bubbler | 07/21/21 | 6:07 | X | | Lead (First Draw) | 1 | P | 250ml | A | 58-11 |
| X | | Closter-12 Room 16a Bubbler | 07/21/21 | 6:08 | X | | Lead (First Draw) | 1 | P | 250ml | A | 58-12 |
| X | | Closter-13 Gym Hall Butte Filter | 07/21/21 | 6:10 | X | | Lead (First Draw) | 1 | P | 250ml | A | 58-13 |
| X | | Closter-14 Gym Hall-Bubbler | 07/21/21 | 6:10 | X | | Lead (First Draw) | 1 | P | 250ml | A | 58-14 |
| X | | Closter-15 Kitchen-SINK | 07/21/21 | 6:11 | X | | Lead (First Draw) | 1 | P | 250ml | A | 58-15 |

*Container Type: P=Plastic G=Glass A=Amber Glass T=Sterile Thro V=Vial Other/Specify: _____
 *Preservation Code: A=Non Preserved B=Sulfuric Acid C=Sodium Hydroxide D=Nitric Acid
 E=Hydrochloric Acid F=Zinc Acetate G=Sodium Inosulfate H=Ascorbic Acid I=Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: XX Standard Rush (If RUSH REQUESTED) Rush Due by: 4 week Turnaround

REPORT FORMAT: Standard Report Other/Specify:

Standard Report + E2 PWS ID#:

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Jerry Bello Signature: *[Signature]*
 Client/Client's Representative (PRINT): Maxx Mazza Signature: *[Signature]* Date/Time:
 1. Received/Relinquished by (PRINT): Signature: *[Signature]* Date/Time:
 2. Received/Relinquished by (PRINT): D. Reaney Signature: *[Signature]* Date/Time: 7/21/21 11:54

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.58
 2020C

Page _____ of _____

GSL CLIENT # CLO02

MICRO #

CHEM. # 210721058-16-20

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Closter Board of Education Contact/Authorized by: Jerry Bello
 Mailing Address: 340 Homans Ave Phone: 973-981-4850
 City/State/Zip: Closter NJ 07624 Email:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Field Blanks **HILLSIDE School**

| Grab | Comp | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | CONTAINER INFORMATION | | | | Lab # |
|------|------|-----------------------------------|-------------------|------|----|----|-----------------------------------|-----------------------|-------|-------|--------|-------|
| | | | Date | Time | AM | PM | | No. | Type* | Size | Pres.* | |
| X | | Closter-21-16 Hallway by C106 | 07/21/21 | 6:12 | X | | Lead (First Draw) | 1 | P | 250ml | A | 5814 |
| X | | Closter-21-17 Hallway by C106 Bub | 07/21/21 | 6:12 | X | | Lead (First Draw) | 1 | P | 250ml | A | 5817 |
| X | | Closter-21-18 Room 100 Bub | 07/21/21 | 6:13 | X | | Lead (First Draw) | 1 | P | 250ml | A | 5818 |
| X | | Closter-21-19 Room 102 Bub | 07/21/21 | 6:14 | X | | Lead (FIRST DRAW) | 1 | P | 250 | A | 5819 |
| X | | Closter-21-20 Hallway D110 BF | 07/21/21 | 6:15 | X | | Lead (FIRST DRAW) | 1 | P | 250 | A | 5820 |

*Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iminosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: **XX** Standard Rush (IF RUSH REQUESTED) Rush Due by: **4 WEEK TURN AROUND**

SEND TO:

REPORT FORMAT: Standard Report Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

| | | |
|---|------------|---------------------------------|
| Sampled by (PRINT): JERRY Bello | Signature: | Date/Time: |
| Client/Client's Representative (PRINT): MAXX mazza | Signature: | Date/Time: |
| 1. Received/Relinquished by (PRINT): | Signature: | Date/Time: |
| 2. Received/Relinquished by (PRINT): D. Prancer | Signature: | Date/Time: 7/21/21 11:54 |

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.5°C
N0200

Page _____ of _____

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

GSL CLIENT # **CLO02**

MICRO #

CHEM. # **210721058-2122**

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **CLOSTER BOARD OF EDUCATION** Contact/Authorized by: **JERRY Bello**
 Mailing Address: **340 HOMANS AVE** Phone: **973-981-4850**
 City/State/Zip: **CLOSTER, NJ 07624** Email: **JERNALTD@aol.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**
 SAMPLE LOCATION: **Hillside School**

| Grab | Comp | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | | CONTAINER INFORMATION | | | |
|------|------|---------------------------|-------------------|------|----|----|--|-------------------|-----------------------|-------|------|--------|
| | | | Date | Time | AM | PM | <input type="checkbox"/> List attached | Total Pages _____ | No. | Type* | Size | Pres.* |
| X | | CLOSTER-1-by D116-bubbler | 07/21/21 | 6:15 | X | | LEAD (FIRST DRAW) | 58-21 | 1 | P | 250 | A |
| X | | CLOSTER-1-Field Blank | 07/21/21 | 6:15 | Y | - | LEAD (FIRST DRAW) | 58-22 | 1 | P | 250 | A |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: **XX** Standard Rush (if RUSH REQUESTED) Rush Due by: **4 WEEKS TURN AROUND**

SEND TO:

REPORT FORMAT: Standard Report Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

| | | |
|---|------------|---------------------------------|
| Sampled by (PRINT): JERRY Bello | Signature: | Date/Time: 07/21/21 |
| Client/Client's Representative (PRINT): maxx mazzo | Signature: | Date/Time: |
| 1. Received/Relinquished by (PRINT): D. R... | Signature: | Date/Time: |
| 2. Received/Relinquished by (PRINT): D. R... | Signature: | Date/Time: 7/21/21 11:54 |

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.3

Page _____ of _____

GSL CLIENT # CLO02

MICRO # _____
 CHEM. # **210721058-23-27**

SAMPLE REC'D BY: _____
 GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Closter Board of Education Contact/Authorized by: Jerry Bello
 Mailing Address: 340 Homans Ave Phone: 973-981-4850
 City/State/Zip: Closter NJ 07624 Email: _____

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Field Blanks - **TENAKILL School**

| Grab | Comp | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | CONTAINER INFORMATION | | | | Lab # Extension |
|------|------|-------------------------------|-------------------|------|----|----|-----------------------------------|-----------------------|-------|-------|--------|--------------------|
| | | | Date | Time | AM | PM | | No. | Type* | Size | Pres.* | |
| X | | 1 FACULTY ROOM SINK | 07/21/21 | 6:40 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-23 |
| x | | 2 NURSE'S ROOM SINK | 07/21/21 | 6:40 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-24 |
| x | | 3 HALLWAY by GYM/OFF Bottle F | 07/21/21 | 6:41 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-25 |
| x | | 4 HALLWAY by GYM/OFF Bubbler | 07/21/21 | 6:41 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-26 |
| x | | 5 Kitchen Prep-SINK | 07/21/21 | 6:43 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-27 |

*Container type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iminosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: **XX** Standard Rush (IF RUSH REQUESTED) Rush Due by: **4 WEEK TURNAROUND**

SEND TO: _____

REPORT FORMAT: Standard Report Other/Specify: _____

DATE/TIME: _____

Standard Report + E2 PWS ID#: _____

METHOD OF SHIPMENT: _____

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note: _____

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

| | | |
|---|------------------|---------------------------------|
| Sampled by (PRINT): JERRY BELLO | Signature: | |
| Client/Client's Representative (PRINT): MAXX MAZZA | Signature: | Date/Time: _____ |
| 1. Received/Relinquished by (PRINT): _____ | Signature: _____ | Date/Time: _____ |
| 2. Received/Relinquished by (PRINT): JAYCO SKELTON | Signature: | Date/Time: 7/21/21 11:54 |

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

NOC
E
OC

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.5

Page _____ of _____

GSL CLIENT # CLO02

MICRO #

CHEM. # 210721058-28-32

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Closter Board of Education Contact/Authorized by: Jerry Bello
 Mailing Address: 340 Homans Ave Phone: 973-981-4850
 City/State/Zip: Closter NJ 07624 Email:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Field Blanks **TENAKILL School**

| Grab | Comp. | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | CONTAINER INFORMATION | | | | Lab # Extension |
|------|-------|--------------------------------|-------------------|------|----|----|-----------------------------------|-----------------------|-------|-------|--------|--------------------|
| | | | Date | Time | AM | PM | | No. | Type* | Size | Pres.* | |
| X | | CLOST-21-6-INGYM-Bottle Filler | 07/21 | 6:43 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-28 |
| X | | CLOST-21-7-INGYM-Bubbler | 07/21/21 | 6:44 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-29 |
| X | | CLOST-21-8 MAIN OFF SINK | 07/21/21 | 6:44 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-30 |
| X | | CLOST-21-9 ByBoiler Hallway-WF | 07/21/21 | 6:45 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-31 |
| X | | CLOST-21-10-Hallway by 206 BF | 07/21/21 | 6:45 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-32 |

*Container Type: P=Plastic G=Glass A=Amber Glass I=Sterile Thro V=Vial Other/Specify: _____
 *Preservation Code: A=Non Preserved B=Sulfuric Acid C=Sodium Hydroxide D=Nitric Acid
 E=Hydrochloric Acid F=Zinc Acetate G=Sodium Iminosulfate H=Ascorbic Acid I=Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: **XX** Standard Rush (IF RUSH REQUESTED) Rush Due by: **4 WEEK TURN AROUND**

SEND TO:

REPORT FORMAT: Standard Report Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): **JERRY BELLO** Signature: *[Signature]*
 Client/Client's Representative (PRINT): **MAX MAZZA** Signature: *[Signature]* Date/Time:
 1. Received/Relinquished by (PRINT): Signature: *[Signature]* Date/Time:
 2. Received/Relinquished by (PRINT): **Joyce O'Keefe** Signature: *[Signature]* Date/Time: 7/21/21 11:54

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, N.JDEP-TN1, NY Dept. of Health #11550 and PADEP #68-03680

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

NO
E
O
C

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 245 No
E
O
C

Page _____ of _____

GSL CLIENT # CLO02

MICRO #

CHEM. # 210721058-33-37

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Closter Board of Education Contact/Authorized by: Jerry Bello
 Mailing Address: 340 Homans Ave Phone: 973-981-4850
 City/State/Zip: Closter NJ 07624 Email:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Field Blanks TENAKILL School

| Grab | Comp | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | CONTAINER INFORMATION | | | | Lab # |
|------|------|------------------------------------|-------------------|------|----|----|-----------------------------------|-----------------------|-------|-------|--------|--------|
| | | | Date | Time | AM | PM | | No. | Type* | Size | Pres.* | |
| X | | CLOST-21-11 HALLWAY by 206-Bubbler | 07/21 | 6:45 | X | | Lead (First Draw) | 1 | P | 250ml | A | 258-35 |
| X | | CLOST-21-12 HALLWAY by B213 WF | 07/21/21 | 6:46 | X | | Lead (First Draw) | 1 | P | 250ml | A | 258-34 |
| X | | CLOST-21-13 HALLWAY by A202 BF | 07/21/21 | 6:47 | X | | Lead (First Draw) | 1 | P | 250ml | A | 258-35 |
| X | | CLOST-21-14 HALLWAY by A202 bub | 07/21/21 | 6:47 | X | | Lead (First Draw) | 1 | P | 250ml | A | 258-36 |
| X | | CLOST-21-15 HALLWAY by A204 BF | 07/21/21 | 6:48 | X | | Lead (First Draw) | 1 | P | 250ml | A | 258-37 |

*Container Type: P=Plastic G=Glass A=Amber Glass S=Sterile Thio V=Vial Other/Specify: _____
 *Preservation Code: A=Non Preserved B=Sulfuric Acid C=Sodium Hydroxide D=Nitric Acid
 E=Hydrochloric Acid F=Zinc Acetate G=Sodium Inosulfate H=Ascorbic Acid I=Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: **XY** Standard Rush (IF RUSH REQUESTED) Rush Due by: **4 WEEK TURN AROUND**

SEND TO:

REPORT FORMAT: Standard Report Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): **JERRY BELLO** Signature: *[Signature]*
 Client/Client's Representative (PRINT): **MAXX MAZZA** Signature: *[Signature]* Date/Time:
 1. Received/Relinquished by (PRINT): Signature: *[Signature]* Date/Time:
 2. Received/Relinquished by (PRINT): *[Signature]* Signature: *[Signature]* Date/Time: 7/21/21 11:54

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/21/21 11:54 24.5

Page _____ of _____

GSL CLIENT # CLO02

MICRO #

CHEM. # 210721058-38,39

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Closter Board of Education Contact/Authorized by: Jerry Bello
 Mailing Address: 340 Homans Ave Phone: 973-981-4850
 City/State/Zip: Closter NJ 07624 Email:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Field Blanks **TENAKill School**

| Grab | Comp. | SAMPLE ID | SAMPLE COLLECTION | | | | ANALYSIS REQUIRED (Print Legibly) | CONTAINER INFORMATION | | | | Lab # Extension |
|------|-------|--------------------------------|-------------------|------|----|----|-----------------------------------|-----------------------|-------|-------|--------|--------------------|
| | | | Date | Time | AM | PM | | No. | Type* | Size | Pres.* | |
| X | | CLOST-21-16-Hallway by A204 bu | 07/21 | 6:48 | X | | Lead (First Draw) | 1 | P | 250ml | A | 058-38 |
| X | | CLOST-21-17-Field Blank | 07/21/21 | 6 | | | Lead (First Draw) | 1 | P | 250ml | A | 058-39 |
| X | | | | | | | Lead (First Draw) | 1 | P | 250ml | A | |
| X | | | | | | | Lead (First Draw) | 1 | P | 250ml | A | |
| X | | | | | | | Lead (First Draw) | 1 | P | 250ml | A | |

*Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iminosulfate H = Ascorbic Acid I = L-Ascorbic Other/Specify: _____

TURNAROUND TIME: **XX** Standard Rush (If RUSH REQUESTED) Rush Due by: **4 WEEK TURNA ROUND**

REPORT FORMAT: Standard Report Other/Specify:

Standard Report + E2 PWS ID#:

SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): **Jerry Bello** Signature: _____ Date/Time: _____
 Client/Client's Representative (PRINT): **MAXX MAZZA** Signature: _____ Date/Time: _____
 1. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: _____
 2. Received/Relinquished by (PRINT): **Joyce Sketow** Signature: _____ Date/Time: **7/21/21 11:54**

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

NO
300C