


# *Lead in Drinking Water Report*

Closter Board of Education  
340 Homans Avenue  
Closter, NJ 07624

August 2024

Prepared for:  
Closter Board of Education  
340 Homans Avenue  
Closter, NJ 07624

Prepared by:  
***New Wave Engineering, LLC***  
**PO Box 4124**  
**Wayne, New Jersey 07474**



August 06, 2024

Mr. Floro Villanueva, Jr.  
Business Administrator  
Closter Board of Education  
240 Homans Avenue  
Closter, NJ 07624

Re: Lead in Drinking Water Services per NJAC 6A:26  
Hillside School, 340 Homans Avenue, Closter, NJ 07624  
Tenakill School, 275 High Street, Closter, NJ 07624

Dear Mr. Villanueva,

New Wave is pleased to submit this lead in drinking water report for the Closter Board of Education. This report details the methods and findings of the comprehensive lead in drinking water services as per New Jersey state regulations (amendments to N.J.A.C 6A:26 Educational Facilities) performed at the various schools in the Closter Public School District, located at the above referenced addresses on July 18, 2024.

Best Regards,

*Nadine Bello*

Nadine Bello, MS, RPIH, CIEC, AST  
*New Wave Engineering, LLC*

## Table of Content

EXECUTIVE SUMMARY.....	Page 1
1.0 PROJECT BACKGROUND.....	Page 2
2.0 LEAD IN DRINKING WATER.....	Page 2
3.0 DRINKING WATER SAMPLING METHODOLOGY.....	Page 3
4.0 DRINKING WATER ANALYSIS RESULTS.....	Page 4
5.0 CONCLUSIONS & RECOMMENDATIONS.....	Page 7
6.0 DISCLAIMER.....	Page 7
7.0 CLOSING.....	Page 8

### APPENDIX A Chain of Custody and Lab Results



## Executive Summary of Lead in Drinking Water Services

August 2024

New Wave Engineering was retained to conduct a first draw “lead in drinking water sampling” at the district’s school buildings located within the Closter Board of Education in July of 2024. Water samples were collected from designated drinking water outlets at the following schools:

All samples were collected according to the regulatory guidelines outlined in the amendments to the N.J.A.C. 6A:26: Educational Facilities (July 2016) and its supporting documentation.

- **Hillside School**
- **Tenakill School**

First draw sample results indicated that water sources sampled at locations from the schools, exhibited no lead levels above the Regulatory Action Level of .015mg/l, or its equivalent: 15ppbs. With no potable water sources in exceedance of the Action Level, no remediation of the water outlets is required. Continue with the Districts plumbing maintenance plan and replace any water filters as required by the manufacture’s recommendations. All plumbing repairs and upgrades must be documented in the district’s “Lead in Drinking Water” plan. According to State regulations, the next scheduled lead in water testing shall occur in three years, during the school year 2027/2028.

## 1.0 PROJECT BACKGROUND

New Wave Engineering was contacted by the Closter Board of Education (the "Client") to perform lead in drinking water sampling to determine the lead content of drinking water from sources throughout the school facilities. Additionally, as per State regulations, New Wave was contracted to update a Quality Assurance Project Plan (QAPP) and a Sampling Plan (SP), including: a Drinking Water Outlet Inventory, Filter Inventory, and Outlet Location Schematic in conjunction with the District's Buildings and Grounds Director.

The purpose of lead in drinking water sampling is to determine if any sampled drinking water sources exhibit lead levels exceeding the Regulatory Action Level of 15 parts per billion (ppb) which may also be designated as: .015mg/l. Drinking water concentration points included: any water sources from which a student, staff, or faculty may reasonably drink or from which the water may be used for cooking or beverage preparation, including, but not limited to, water coolers/bubblers, kitchen faucets, Nurse's Office faucets, and Faculty/Staff lounges.

For further information on guidance protocols and Action Levels that were followed please refer to: The EPA's Revised Technical Guidance - *"3Ts for Reduced Lead in Drinking Water in Schools"* and the Guidance Document from NJDEP Division of Water Supply and Geoscience — *"Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water"*.

## 2.0 LEAD IN DRINKING WATER

Lead is a toxic substance that can be harmful to human health. As compared to adults, children are more susceptible to the detrimental health effects of lead, as their nervous systems are not yet fully developed. Exposure to lead can occur in a variety of ways including through food, soil, deteriorating lead-based paint, and drinking water. Lead can leach into drinking water from plumbing materials such as pipes and solder, as well as brass plumbing fixtures. For this investigation, planning, preparation, methodology, sampling, and follow up actions were conducted according to the technical guidance provided by New Jersey following the adoption of amendments to N.J.A.C. 6A:26: *"Educational Facilities, requiring the sampling of drinking water for Lead in Schools"*

### 3.0 DRINKING WATER SAMPLING METHODOLOGY

New Wave collected drinking water samples from water outlets throughout each school building. At each collection point, New Wave filled a 250 milliliter (ml) wide-mouth high density polyethylene (HDPE) sample collection bottle from the designated water source. Samples were collected after the water in each building had not been used for at least 8 hours, but not more than 48 hours. The initial sample at each collection point represents the first draw sample. The first draw sample is representative of the water from the end point of the water source (i.e., the bubbler/bottle filler or tap).

A field blank using lead-free laboratory reagent water was also collected for each Facility during the sampling event to rule out contamination of samples during the collection and transportation process. All samples were recorded utilizing proper chain of custody documents and couriered to *Garden State Laboratory*, a New Jersey certified laboratory (NJ Lab ID #20044) located in Hillside, New Jersey for analysis via EPA method 200.80.

During the initial sampling event on July 21, New Wave collected the following number of samples at each School Building:

#### **Hillside School**

- 1) 21 First draw samples
- 2) 1 Field Blank Sample

#### **Tenakill School**

- 1) 16 First draw samples
- 2) 1 Field Blank Sample

For a complete drinking water outlet inventory and sampling location diagram for each facility, please refer to the Sampling Plan, dated May 2017. Updates to this documentation can be found in the Field Log Book for each facility.

## 4.0 DRINKING WATER ANALYSIS RESULTS

The analytical “lead in drinking water results” for each first draw sample is listed in Tables below:

Table 1: Analytical Lead Results for First Draw Water Samples Collected from **Hillside School** July 18, 2024

Sample I.D.	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
CLOS-HS-24-01	Hallway C136 W/F left	< 0.00100	No
CLOS-HS-24-02	Hallway C136 W/F right	< 0.00100	No
CLOS-HS-24-03	Rm 136 Bubblers	< 0.00100	No
CLOS-HS-24-04	Nurse’s Office Sink	< 0.01000	No
CLOS-HS-24-05	Copy Room Sink	< 0.00100	No
CLOS-HS-24-06	Room 137 Bubblers	< 0.00100	No
CLOS-HS-24-07	Room 138 Bubblers	< 0.01000	No
CLOS-HS-24-08	Room 141 Bubblers	< 0.00100	No
CLOS-HS-24-09	Room 153 Bubblers	< 0.00100	No
CLOS-HS-24-10	Room 156 Bubblers	< 0.00100	No
CLOS-HS-24-11	Room 159 Bubblers	< 0.00100	No
CLOS-HS-24-12	Room 162 Bubblers	< 0.00100	No
CLOS-HS-24-13	Gym Hall B/F	< 0.00100	No
CLOS-HS-24-14	Gym Hall Bubblers	< 0.00100	No
CLOS-HS-24-15	Kitchen Sink	< 0.00100	No
CLOS-HS-24-16	Hallway by C106 B/F	< 0.00100	No
CLOS-HS-24-17	Hallway by C106 Bubblers	< 0.00100	No
CLOS-HS-24-18	Room 100 Bubblers	< 0.00100	No
CLOS-HS-24-19	Room 102 Bubblers	< 0.00100	No
CLOS-HS-24-20	Hallway D110 B/F	< 0.00100	No
CLOS-HS-24-21	Hallway D110 Bubblers	< 0.00100	No
CLOS-HS-24-22	FIELD BLANK	< 0.00100	No

BF= Bottle Filler Station    W/F= Water Fountain    B= Bubblers    S=Sink



Table 2: Analytical Lead Results for First Draw Water Samples  
Collected from **Tenakill School** taken on July 18, 2024

Sample ID.	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
CLOS-T-24-01	Faculty Room Sink	< 0.00100	No
CLOS-T-24-02	Nurse's Room Sink	< 0.00119	No
CLOS-T-24-03	Hallway by Gym B/F	< 0.00100	No
CLOS-T-24-04	Hallway by Gym Bubbler	< 0.00100	No
CLOS-T-24-05	Kitchen Prep Sink	< 0.00100	No
CLOS-T-24-06	In Gym B/F	< 0.00100	No
CLOS-T-24-07	In Gym Bubbler	< 0.00100	No
CLOS-T-24-08	Main Office Sink	< 0.00100	No
CLOS-T-24-09	Boiler Hallway W/F	< 0.00100	No
CLOS-T-24-10	Hallway by 206 B/F	< 0.00100	No
CLOS-T-24-11	Hallway by 206 Bubbler	< 0.00100	No
CLOS-T-24-12	Hallway by B213 W/F	< 0.00100	No
CLOS-T-24-13	Hallway by 202 B/F	< 0.00100	No
CLOS-T-24-14	Hallway by B202 Bubbler	< 0.00100	No
CLOS-T-24-15	Hallway by A204 B/F	< 0.00100	No
CLOS-T-24-16	Hallway by A204 Bubbler	< 0.00100	No
CLOS-T-24-17	FIELD BLANK	< 0.00100	No

B/F= Bottle Filler    B= Bubbler    W/F= Water Fountain    S= Sink

All laboratory analytical results of first-draw samples were compared to the NJDEP's Regulatory Action Level of 15.5 ppb or .015 mg/l for lead. Analysis of lead in the first draw drinking water samples indicated that, at the time of the sampling event, no water sources tested exceeded the action level.

## 5.0 CONCLUSIONS & RECOMMENDATIONS

New Wave collected first draw samples from drinking water sources throughout the Closter Board of Education school facilities. First draw sample results indicated that no water outlet sources *exceeded* the regulatory action level of 15 ppb or .015mg/l. In conclusion of the comprehensive “lead in drinking water” services, New Wave offers the following recommendations:

- Continue to monitor lead in drinking water levels as part of a regular sampling and maintenance plan, per New Jersey State regulations.
- Implement an aerator cleaning maintenance program to prevent the build up of debris behind the aerator screen which may contribute to elevated lead levels.
- Enter all filter maintenance, aerator maintenance, plumbing repairs/changes and any other important information into the Field Log Book for each School.
- Use only cold water for food and beverage preparation, as hot water is more likely to contribute to the corrosion of plumbing materials and therefore may contain a greater level of water contaminants from the plumbing system.

## 6.0 Disclaimer

This investigation focused on lead in drinking water. No other heavy metals or additional contaminants were sampled for/or analyzed. Note: Lead concentrations in water can change as water continues to move through the water system.

Each sample taken was a “grab sample” and represents lead concentrations only at the specific time of collection and may vary based upon the water usage in the facility. Interpretation of these results is only valid if the facility is serviced by a municipal water supplier or water utility.

Our lead sampling event was in response to recent amendments to N.J.A.C. 6A:26i *Educational Facilities* dated July 13, 2016, which requires testing for lead in drinking water of public and charter school districts with retesting every three years.

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment.

New Wave Engineering, LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for the above noted client. New Wave Engineering, LLC assumes no liability with regards

to the use of this information or decisions which are made regarding the subject properties. It is at the discretion of the School District, given the results and information in this report, to use their own best judgment to determine any appropriate course of action.

## **7.0 Closing**

The drinking water in the Closter Public Schools is below the action level of 15 ppb or .015 mg/l.

Thank you for utilizing New Wave to assist your District with this project. Please do not hesitate to call if you have any questions relating to this report or for any other environmental health and safety concerns.

APPENDIX A  
CHAIN OF CUSTODY  
AND  
LAB RESULTS



# Garden State Laboratories, Inc.

## Report of Analysis

410 Hillside Ave.  
Hillside, NJ 07205

Telephone: 800-273-8901  
Email: info@gsllabs.com  
Internet: www.gsllabs.com

Main Lab  
NJDEP Lab Cert. #20044

Jersey Shore Lab  
NJDEP Lab Cert. #15037

Lakehurst Lab  
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A. Laboratory Manager

For: Closter Board of Education - NW  
340 Homans Ave

Closter, NJ 07624

Laboratory Director:

Attention: Jerry Bello

Client Number: CLO02

Report Date: 07/24/2024

Sample ID: TENAKILL School 275 High  
Street Closter NJ, Clos-Ten-24-  
01 Faculty Rm Sink

Lab Sample ID: 240718093-01

Site: Collection Date/Time: 07/18/2024 07:08

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:19	

Sample ID: TENAKILL School 275 High  
Street Closter NJ, Clos-Ten-24-  
02 nurse's Rm Sink

Lab Sample ID: 240718093-02

Site: Collection Date/Time: 07/18/2024 07:09

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:22	

Sample ID: TENAKILL School 275 High  
Street Closter NJ, Clos-Ten-24-  
03 Hallway by Gym B/F

Lab Sample ID: 240718093-03

Site: Collection Date/Time: 07/18/2024 07:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:25	

Sample ID: TENAKILL School 275 High  
Street Closter NJ, Clos-Ten-24-  
04 Hallway by Gym bubbler

Lab Sample ID: 240718093-04

Site: Collection Date/Time: 07/18/2024 07:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:27	



Garden State Laboratories, Inc.

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-05 Kitchen Prep Sink Lab Sample ID: 240718093-05

Site: Collection Date/Time: 07/18/2024 07:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:30	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-06 In Gym B/F Lab Sample ID: 240718093-06

Site: Collection Date/Time: 07/18/2024 07:12

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:42	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-07 In Gym bubbler Lab Sample ID: 240718093-07

Site: Collection Date/Time: 07/18/2024 07:12

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:47	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-08 Main Office Sink Lab Sample ID: 240718093-08

Site: Collection Date/Time: 07/18/2024 07:13

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:50	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-09 Boiler Hallway B/F Lab Sample ID: 240718093-09

Site: Collection Date/Time: 07/18/2024 07:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:53	



Garden State Laboratories, Inc.

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-10 Boiler Hallway bubbler

Lab Sample ID: 240718093-10

Site: Collection Date/Time: 07/18/2024 07:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 12:56	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-11 Hallway by 206 B/F

Lab Sample ID: 240718093-11

Site: Collection Date/Time: 07/18/2024 07:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:05	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-12 Hallway by 206 bubbler

Lab Sample ID: 240718093-12

Site: Collection Date/Time: 07/18/2024 07:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:07	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-13 Hallway by 213 W/F

Lab Sample ID: 240718093-13

Site: Collection Date/Time: 07/18/2024 07:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:16	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-14 Hallway by 202 B/F

Lab Sample ID: 240718093-14

Site: Collection Date/Time: 07/18/2024 07:19

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:19	



Garden State Laboratories, Inc.

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-15 Hallway by 202 bubbler

Lab Sample ID: 240718093-15

Site: Collection Date/Time: 07/18/2024 07:19

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:21	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-16 Hallway by A204 B/F

Lab Sample ID: 240718093-16

Site: Collection Date/Time: 07/18/2024 07:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:24	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-17 Hallway by A204 bubbler

Lab Sample ID: 240718093-17

Site: Collection Date/Time: 07/18/2024 07:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:27	

Sample ID: TENAKILL School 275 High Street Closter NJ, Clos-Ten-24-18 Field blank

Lab Sample ID: 240718093-18

Site: Collection Date/Time: 07/18/2024 07:21

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:30	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-01 Hallway C136 W/F left

Lab Sample ID: 240718093-19

Site: Collection Date/Time: 07/18/2024 06:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:33	





Garden State Laboratories, Inc.

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-02 Hallway C136 W/F right

Lab Sample ID: 240718093-20

Site: Collection Date/Time: 07/18/2024 06:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:36	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-03 Room 136 bubbler

Lab Sample ID: 240718093-21

Site: Collection Date/Time: 07/18/2024 06:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:38	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-04 Nurse's Sink

Lab Sample ID: 240718093-22

Site: Collection Date/Time: 07/18/2024 06:34

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:41	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-05 Copy Room Sink

Lab Sample ID: 240718093-23

Site: Collection Date/Time: 07/18/2024 06:34

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:53	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-06 Room 137 Bubbler

Lab Sample ID: 240718093-24

Site: Collection Date/Time: 07/18/2024 06:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:55	



Garden State Laboratories, Inc.

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-07 Room 138 Bubbler Lab Sample ID: 240718093-25

Site: Collection Date/Time: 07/18/2024 06:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 13:58	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-08 Room 141 Bubbler Lab Sample ID: 240718093-26

Site: Collection Date/Time: 07/18/2024 06:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:01	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-09 Room 153 Bubbler Lab Sample ID: 240718093-27

Site: Collection Date/Time: 07/18/2024 06:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:07	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-10 Room 156 Bubbler Lab Sample ID: 240718093-28

Site: Collection Date/Time: 07/18/2024 06:37

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:16	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-11 Room 159 Bubbler Lab Sample ID: 240718093-29

Site: Collection Date/Time: 07/18/2024 06:37

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:18	



Garden State Laboratories, Inc.

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-12 Room 162 Bubbler Lab Sample ID: 240718093-30

Site: Collection Date/Time: 07/18/2024 06:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:27	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-13 Gym Hall B/F Lab Sample ID: 240718093-31

Site: Collection Date/Time: 07/18/2024 06:42

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:30	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-14 Gym Hall Bubbler Lab Sample ID: 240718093-32

Site: Collection Date/Time: 07/18/2024 06:43

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:32	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-15 Kitchen Sink Lab Sample ID: 240718093-33

Site: Collection Date/Time: 07/18/2024 06:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:35	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-16 Hallway C106 B/F Lab Sample ID: 240718093-34

Site: Collection Date/Time: 07/18/2024 06:47

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:38	



Garden State Laboratories, Inc.

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-17 Hallway C106 Bubbler

Lab Sample ID: 240718093-35

Site: Collection Date/Time: 07/18/2024 06:48

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:41	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-18 Room P100 Bubbler

Lab Sample ID: 240718093-36

Site: Collection Date/Time: 07/18/2024 06:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:44	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-19 Room P102 Bubbler

Lab Sample ID: 240718093-37

Site: Collection Date/Time: 07/18/2024 06:51

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:46	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-20 Hallway D110 B/F

Lab Sample ID: 240718093-38

Site: Collection Date/Time: 07/18/2024 06:52

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 14:49	

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-21 Hallway D110 Bubbler

Lab Sample ID: 240718093-39

Site: Collection Date/Time: 07/18/2024 06:52

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 15:02	



Garden State Laboratories, Inc.

Sample ID: Hillside school 340 Homans Avenue Closter NJ, Clos-Hs-24-22 Field Blank  
Lab Sample ID: 240718093-40  
Site: Collection Date/Time: 07/18/2024 06:52  
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	07/23/24 15:04	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.  
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7-18-24 13:34 28.1

J. Moll

Page of

GSL CLIENT # C1002

MICRO #

CHEM 240718093-01-

SAMPLE REC'D BY: CS

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: CLOSTER Board of Education Contact/Authorized by: Jerry Bello

Mailing Address: 340 Homan's Avenue Phone: 973-981-4850

City/State/Zip: CLOSTER, New Jersey 07624 Email: JERRY@newwave

### SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: TENAKILL School 275 HIGH STREET CLOSTER NJ

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
		Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X	Clos-TEN-24-01 Faculty Rm Sink	07/18/24	7:08	X		LEAD FIRST DRAW	03-01	1	P	250ML	A
X	Clos-TEN-24-02 Nurse's Rm Sink	07/18/24	7:09	X		LEAD FIRST DRAW	03-02	1	P	250ML	A
X	Clos-TEN-24-03 Hallway by Gym B/F	07/18/24	7:10	X		LEAD FIRST DRAW	03-03	1	P	250ML	A
X	Clos-TEN-24-04 Hallway by Gym bubbler	07/18/24	7:10	X		LEAD FIRST DRAW	03-04	1	P	250ML	A
X	Clos-TEN-24-05 Kitchen Prep Sink	07/18/24	7:11	X		LEAD FIRST DRAW	03-05	1	P	250ML	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify:  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

### PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT):	NADINE BELLO	Signature:	<i>Nadine Bello</i>	Date/Time:	07/18/2024
Client/Client's Representative (PRINT):	NADINE BELLO	Signature:	<i>Nadine Bello</i>	Date/Time:	07/18/2024
1. Received/Relinquished by (PRINT):		Signature:		Date/Time:	
2. Received/Relinquished by (PRINT):	Jaelon Moll	Signature:	<i>J. Moll</i>	Date/Time:	7-18-24 13:34



CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLER RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7-18-24 13:34 28.1

2. Moll

Page of

GSL CLIENT # CL002

MICRO#

CHEM. 8407180012-06

SAMPLE REC'D BY: 10

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

Name: CLOSTER BOARD OF EDUCATION Contact/Authorized by: Jerry Bello

Mailing Address: 340 Homans Avenue Phone: 973 981 4850

City/State/Zip: CLOSTER NEW JERSEY 07624 Email: JERRY@newwave

environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: TENAKILL School 275 HIGH STREET CLOSTER NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		Clos-Ten-24-06 In Gym B/F	07/18/24	7:12	X		LEAD FIRST DRAW	Q3-06	1	P	250ml	A
X		Clos-Ten-24-07 In Gym bubbler	07/18/24	7:12	X		LEAD FIRST DRAW	Q3-07	1	P	250ml	A
X		Clos-Ten-24-08 Main Office Sink	07/18/24	7:13	X		LEAD FIRST DRAW	Q3-08	1	P	250ml	A
X		Clos-Ten-24-09 Boiler hallway B/F	07/18/24	7:15	X		LEAD FIRST DRAW	Q3-09	1	P	250ml	A
X		Clos-Ten-24-10 Boiler hallway bubbler	07/18/24	7:15	X		LEAD FIRST DRAW	Q3-10	1	P	250ml	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify:  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

## PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

Client/Client's Representative (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

1. Received/Relinquished by (PRINT):

Signature:

Date/Time:

2. Received/Relinquished by (PRINT): JASON MOECH

Signature: Jason Moeck

Date/Time: 7-18-24 13:24

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7-18-24 13:34 28.1

J. Moeck

Page of

GSL CLIENT # C1002

MICRO #

CHEM: # 04078098-VI

SAMPLE REC'D BY: IS

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

## CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: CLOSTER BOARD OF Education Contact/Authorized by: JERRY Bello

Mailing Address: 340 Homans Avenue Phone: 973 981-4850

City/State/Zip: CLOSTER, New Jersey 07624 Email: JERRY@newwave

SAMPLE INFORMATION environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: TENAKILL School 275 HIGH Street CLOSTER NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		Clos-Ten-24-11 Hallway by 206 B/F	07/18/24	7:17	X		LEAD FIRST DRAW	03-11	1	P	250ml	A
X		Clos-Ten-24-12 Hallway by 206 bubbler	07/18/24	7:17	X		LEAD FIRST DRAW	03-12	1	P	250ml	A
X		Clos-Ten-24-13 Hallway by 213 w/F	07/18/24	7:18	X		LEAD FIRST DRAW	03-13	1	P	250ml	A
X		Clos-Ten-24-14 Hallway by 202 B/F	07/18/24	7:19	X		LEAD FIRST DRAW	03-14	1	P	250ml	A
X		Clos-Ten-24-15 Hallway by 202 bubbler	07/18/24	7:19	X		LEAD FIRST DRAW	03-15	1	P	250ml	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify:

\*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

## PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

Client/Client's Representative (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

1. Received/Relinquished by (PRINT):

Signature:

Date/Time:

2. Received/Relinquished by (PRINT): JASON MOECK

Signature: J. Moeck

Date/Time: 7-18-24 13:34



CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7-18-24 13:34 98.1

J. Hall

Page of

GSL CLIENT # C1602

MICRO #

CHEM. # 2407180013-16

SAMPLE REC'D BY: 18

☐ GSL FIELD SAMPLER/PICK-UP☐ PICK-UP AT DROP OFF LOCATION☒ DELIVERED BY CLIENT

## CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: CLOSTER Board of Education Contact/Authorized by: Jerry Bello

Mailing Address: 340 Homans Avenue Phone: 973-981-4850

City/State/Zip: CLOSTER, New Jersey 07624 Email: Jerry@Newwave

SAMPLE INFORMATION Environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: TENAKILL SCHOOL 275 HIGH STREET CLOSTER, N.J.

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		Clos-Ten-24-16 Hallway by A204 b/f	7-18-24	7:20	X		Lead-First DRAW	93-16	1	P	250ml	A
X		Clos-Ten-24-17 Hallway by A204 bubbles	7-18-24	7:20	X		Lead-First DRAW	93-17	1	P	250ml	A
X		Clos-Ten-24-18 Field blank	7-18-24	7:21	X		Field blank lead	93-18	1	P	250ml	

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_

\*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:☐ Standard Report + E2 PWS ID#:

## PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): NADINE BELLO Signature: Nadine Bello Date/Time: 07/18/2024

Client/Client's Representative (PRINT): NADINE BELLO Signature: Nadine Bello Date/Time: 07/18/2024

1. Received/Relinquished by (PRINT): Signature: Date/Time:

2. Received/Relinquished by (PRINT): Jellon Macch Signature: J. Hall Date/Time: 7-18-24

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB

7/18/24 18:34 88.1c  
NOB00

Page of

GSL CLIENT # C1002

MICRO #

CHEM. # 240718093-19-

SAMPLE REC'D BY: 23

☐ GSL FIELD SAMPLER/PICK-UP☐ PICK-UP AT DROP-OFF LOCATION☒ DELIVERED BY CLIENT

## CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: CLOSTER Board of Education

Contact/Authorized by: JERRY Bello

Mailing Address: 340 Homans Avenue

Phone: 973-981-4850

City/State/Zip: CLOSTER, New Jersey 07624

Email: JERRY@newwave

## SAMPLE INFORMATION

Environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: HILLSIDE SCHOOL 340 Homans Avenue Closter New Jersey

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		Clos-HS-24-01-Hallway C136 W/F left	07/18/24	6:32	X		<input checked="" type="checkbox"/> LEAD FIRST DRAW	93-101	1	P	250ml	A
X		Clos-HS-24-02-Hallway C136 W/F right	07/18/24	6:32	Y		<input checked="" type="checkbox"/> LEAD FIRST DRAW	93-201	1	P	250ml	A
X		Clos-HS-24-03 Room 136 Bubble	07/18/24	6:33	X		<input checked="" type="checkbox"/> LEAD FIRST DRAW	93-21	1	P	250ml	A
X		Clos-HS-24-04 Nurse's Sink	07/18/24	6:34	X		<input checked="" type="checkbox"/> LEAD FIRST DRAW	93-22	1	P	250ml	A
X		Clos-HS-24-05 Copy Room Sink	07/18/24	6:34	Y		<input checked="" type="checkbox"/> LEAD FIRST DRAW	93-23	1	P	250ml	A

⇒ \*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify:

⇒ \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

TURNAROUND TIME:

☒ Standard☐ Rush

(IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT:

☒ Standard Report☐ Other/Specify:☐ Standard Report + E2

PWS ID#:

## PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$☐ Composite Fee: \$☐ Rush Fee: \$

Amount Due: \$

Payment Method: ☐ Credit Card Type:☐ Check #☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): MADINE BELLO

Signature: *Madine Bello*

Date/Time: 07/18/2024

Client/Client's Representative (PRINT): MADINE BELLO

Signature: *Madine Bello*

Date/Time: 07/18/2024

1. Received/Relinquished by (PRINT):

Signature: *[Signature]*

Date/Time:

2. Received/Relinquished by (PRINT):

Signature: *[Signature]*

Date/Time: 7/18/24 18:34

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
 Tel: 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/18/24 13:34 28.1

NO EOC

Page of

GSL CLIENT # CL 002

MICRO #

CHEM. # 240718093-24

SAMPLE REC'D BY: 28

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

## CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: CLOSTER BOARD OF EDUCATION Contact/Authorized by: JERRY Bello

Mailing Address: 340 HOMANS AVENUE Phone: 973-981-4850

City/State/Zip: CLOSTER, NEW JERSEY 07624 Email: JERRY@NEWWAVEENVIRONMENTAL.COM

## SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Hillside School 340 Homans Avenue Closter, New Jersey

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION			
			Date	Time	AM	PM		No.	Type*	Size	Pres.*
X		Clos+HS-24-06 Room 137 Bubbler	07/18/24	6:35	X		LEAD FIRST DRAW Q3-24	1	P	250mL	A
X		Clos+HS-24-07 Room 138 Bubbler	07/18/24	6:35	X		LEAD FIRST DRAW Q3-25	1	P	250mL	A
X		Clos+HS-24-08 Room 141 Bubbler	07/18/24	6:36	X		LEAD FIRST DRAW Q3-26	1	P	250mL	A
X		Clos+HS-24-09 Room 153 Bubbler	07/18/24	6:36	X		LEAD FIRST DRAW Q3-27	1	P	250mL	A
X		Clos+HS-24-10 Room 156 Bubbler	07/18/24	6:37	X		LEAD FIRST DRAW Q3-28	1	P	250mL	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_

\*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by: \_\_\_\_\_

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: \_\_\_\_\_

☐ Standard Report + E2 PWSID#: \_\_\_\_\_

## PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note: \_\_\_\_\_

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): NADINE BELLO Signature: *Nadine Bello* Date/Time: 07/18/2024

Client/Client's Representative (PRINT): NADINE BELLO Signature: *Nadine Bello* Date/Time: 07/18/2024

1. Received/Relinquished by (PRINT): Signature: *[Signature]* Date/Time: \_\_\_\_\_

2. Received/Relinquished by (PRINT): Signature: *[Signature]* Date/Time: 7/18/24 13:34



CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/18/24 13:34 28.1c  
NOBDC

Page of

GSL CLIENT # CLOO2

MICRO #

CHEM. # 240718093-29-

SAMPLE REC'D BY: 33

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

## CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: CLOSTER Board of Education Contact/Authorized by: JERRY Bello

Mailing Address: 340 HOMANS AVENUE Phone: 973-981-4850

City/State/Zip: CLOSTER, New Jersey 07624 Email: JERRY@newwaveenviro

mental.com

## SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Hillside School 340 Homans Avenue Closter New Jersey

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		Clos HS-24-11-Room 159 Bubbler	07/18/24	6:37	X			718/24	1	P	250ml	A
X		Clos HS-24-12 Room 162 Bubbler	07/18/24	6:38	X			718/24	1	P	250ml	A
X		Clos HS-24-13 GYM HALL B/F	07/18/24	6:42	X			718/24	1	P	250ml	A
X		Clos HS-24-14 GYM HALL Bubbler	07/18/24	6:43	X			718/24	1	P	250ml	A
X		Clos HS-24-15 Kitchen Sink	07/18/24	6:45	X			718/24	1	P	250ml	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_

\*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by: \_\_\_\_\_

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: \_\_\_\_\_

☐ Standard Report + E2 PWS ID#: \_\_\_\_\_

## PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note: \_\_\_\_\_

☐ SUBCONTRACTED WORK

SEND TO: \_\_\_\_\_

DATE/TIME: \_\_\_\_\_

METHOD OF SHIPMENT: \_\_\_\_\_

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

Client/Client's Representative (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

1. Received/Relinquished by (PRINT):

Signature:

Date/Time:

2. Received/Relinquished by (PRINT):

Signature:

Date/Time: 7/18/24 13:34



CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP REC'D AT LAB:

7/18/24 13:34 28.1C  
NADINE

Page of

GSL CLIENT # C1002

MICRO#

CHEM: #2407180013-34

SAMPLE REC'D BY: 38

☐ GSL FIELD SAMPLER/PICK-UP☐ PICK-UP AT DROP OFF LOCATION☒ DELIVERED BY CLIENT

Name: CLOSTER BOARD OF EDUCATION

Contact/Authorized by: JERRY BELLO

Mailing Address: 340 HOMANS AVENUE

Phone: 973-981-4850

City/State/Zip: CLOSTER, NEW JERSEY 07624

Email: JERRY@newwave

SAMPLE INFORMATION: Environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: HILLSIDE SCHOOL 340 HOMANS AVENUE CLOSTER New Jersey

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		Clos-HS-24-16 Hallway C 106 B/F	07/18/24	6:47	X		LEAD - FIRST DRAW	93-34	1	P	250ml	A
X		Clos-HS-24-17 Hallway C 106 bubbles	07/18/24	6:48	X		LEAD FIRST DRAW	93-35	1	P	250ml	A
X		Clos-HS-24-18 Room P100 Bubbles	07/18/24	6:50	X		LEAD FIRST DRAW	93-36	1	P	250ml	A
X		Clos-HS-24-19 Room P102 Bubbles	07/18/24	6:51	X		LEAD FIRST DRAW	93-37	1	P	250ml	A
X		Clos-HS-24-20 Hallway D 110 B/F	07/18/24	6:52	X		LEAD FIRST DRAW	93-38	1	P	250ml	A

⇒ \*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_

⇒ \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:☐ Standard Report + E2 PWSID#:

## PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

Client/Client's Representative (PRINT): NADINE BELLO

Signature: Nadine Bello

Date/Time: 07/18/2024

1. Received/Relinquished by (PRINT):

Signature:

Date/Time:

2. Received/Relinquished by (PRINT):

Signature:

Date/Time: 7/18/24 13:34

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab. Cert. #20044  
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

7/18/24 13:34 28.1c  
 NOBDOC

Page of

GSL CLIENT # C1002

MICRO#

CHEM. # 240718098-39

SAMPLE REC'D BY: 40

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Cluster Based of Education Contact/Authorized by: Jerry Bello

Mailing Address: 340 Homans Avenue Phone: 973-981-4850

City/State/Zip: Closter, New Jersey 07624 Email: jerry@newwave

environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: Hillside School

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
		Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
✓	Cls-MS-24-21-Hallway D 110 bubbles	07/18/24	6:52	X		LEAD FIRST DRAW 93-39		1	P	250mL	A
✓	Cls MS 24-22 Field Blank	07-18-24	6:52	X		Field Blank-Lead 93-40		1	P	250mL	

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWSID#:

### PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT):	NADINE BELLO	Signature:	<i>Nadine Bello</i>	Date/Time:	07/18/2024
Client/Client's Representative (PRINT):	NADINE BELLO	Signature:	<i>Nadine Bello</i>	Date/Time:	07/18/2024
1. Received/Relinquished by (PRINT):		Signature:		Date/Time:	
2. Received/Relinquished by (PRINT):		Signature:		Date/Time:	7/18/24 13:34